

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Multi Mode Inverter

Name and address of the applicant

Victron Energy B.V.
De Paal 35, 1351 JG Almere
Netherlands

Name and address of the manufacturer

Victron Energy B.V.
De Paal 35, 1351 JG Almere
Netherlands

Name and address of the factory

Note: When more than one factory, please report on page 2

☐ Additional information on page 2

Ratings and principal characteristics

Quattro 48/8000/110-100/100 230V VE.Bus:
DC IN: 38-66 V, 188 A
AC OUT 1/2: 230 V, 30 A, 50/60 Hz, 8000 VA/6400 W
AC IN 1/2 : 187-250 V, 100 A/100 A, 50/60 Hz, 6400 VA/6400 W
DC OUT: 48 V, 110 A

Quattro 48/10000/140-100/100 230V VE.Bus
DC IN: 38-66 V, 235 A
AC OUT 1/2: 230 V, 37 A, 50/60 Hz, 10 kVA/8 kW
AC IN 1/2 : 187-250 V, 100 A/100 A, 50/60 Hz, 8 kVA/8 kW
DC OUT: 48 V, 140 A

Quattro 48/15000/200-100/100 230V VE.Bus
DC IN: 38-66 V, 350 A
AC OUT 1/2: 230 V, 53/50 A, 50/60 Hz, 15 kVA/12 kW
AC IN 1/2 : 187-250 V, 100 A/100 A, 50/60 Hz, 12 kVA/12 kW
DC OUT: 48 V, 200 A

Trademark / Brand (if any)

Victron Energy

Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

Quattro 48/8000/110-100/100 230V VE.Bus
Quattro 48/10000/140-100/100 230V VE.Bus
Quattro 48/15000/200-100/100 230V VE.Bus

Additional information (if necessary may also be reported on page 2)

☐ Additional information on page 2

A sample of the product was tested and found to be in conformity with

IEC 62109-1:2010, IEC 62109-2:2011

As shown in the Test Report Ref. No. which forms part of this Certificate

15PP007-10_0
15PP007-11_0

This CB Test Certificate is issued by the National Certification Body

Kiwa Nederland B.V.
Wilmersdorf 50
NL - 7327 AC Apeldoorn
Netherlands




- Digitally signed | see <http://ca.kiwa-deutschland.de> for more details -

Date: 2025-07-30

Signature: Raphael Rader